

## Code Change No: **G38-09/10**

### Original Proposal

**Section(s): 402.11**

**Proponent:** Marcelo M. Hirschler, GBH International

**Revise as follows:**

**402.11 Kiosks.** Kiosks and similar structures (temporary or permanent) shall meet the following requirements:

1. Combustible kiosks or other structures shall not be located within the mall unless constructed of any of the following materials:
  - 1.1. Fire-retardant-treated wood complying with Section 2303.2.
  - 1.2. Foam plastics having a maximum heat release rate not greater than 100kW (105 Btu/h) when tested in accordance with the exhibit booth protocol in UL 1975.
  - 1.3. Aluminum composite material (ACM) meeting the requirements of Class A interior finish in accordance with Chapter 8 having a flame-spread index of not more than 25 and a smoke-developed index of not more than 450 when tested as an assembly in the maximum thickness intended for use in accordance with ASTM E 84 or UL 723.
2. Kiosks or similar structures located within the mall shall be provided with *approved* fire suppression and detection devices.
3. The minimum horizontal separation between kiosks or groupings thereof and other structures within the mall shall be 20 feet (6096 mm).
4. Each kiosk or similar structure or groupings thereof shall have a maximum area of 300 square feet (28 m<sup>2</sup>).

**Reason:** This is simply an editorial clarification, to make the requirement more consistent with other requirements in the code and to make it more generic. There are no changes in requirements. This is also consistent with Section 402.12.1.

**Cost Impact:** The code change proposal will not increase the cost of construction.

### Public Hearing Results

**Committee Action:**

**Approved as Submitted**

**Committee Reason:** The change provides consistency with Section 402.12.1.

**Assembly Action:**

**None**

### Final Hearing Results

**G38-09/10**

**AS**