

GEW123-14

608.9

Proponent: Glenn Heinmiller, representing International Association of Lighting Designers
(glenn@lampartners.com)

Revise as follows:

608.9 Exterior lighting. Exterior lighting on building sites shall comply with the lighting power and control requirements of Sections C405.6.1 and C405.6.2 of the *International Energy Conservation Code* regardless of how the power for that lighting is supplied.

Exception: Lighting for the following purposes is exempt:

1. Where *approved* because of historical, safety, signage, or emergency lighting considerations.
2. Roadway lighting required by governmental authorities.

Reason: The proposed change is editorial in nature. The Section reference is more general, and the language indicates what type of requirements will be found in Section C405.6. This will make the code easier to use because users will not need to refer to the IECC to understand what this requirement means.

The IgCC is unique in that it includes the entirety of building sites within its' scope, whereas the IECC only includes lighting that is powered from the building's electrical service, which is why this section of the IgCC is necessary.

Cost Impact: Will not increase the cost of construction.

Analysis: The International Energy Conservation Code section C405.6 referenced in the text of this proposal are section numbers for the 2012 Edition. Due to significant changes approved for the 2015 IECC, the section number for the 2015 Editions will be C405.5.

GEW123-14: 608.9-HEINMILLER674