

# GEW158-14

## 702.7

**Proponent:** Dru Meadows, The Green Team, Inc., representing Walmart  
(dmeadows@thegreenteaminc.com)

**Revise as follows:**

**702.7 709.11 Municipal reclaimed water.** Where required by Table 302.1 and where municipal reclaimed water is accessible and allowed for such use by the laws, rules and ordinances applicable in the jurisdiction, it shall be supplied to water closets, water-supplied urinals, water-supplied trap primers and applicable industrial uses. A municipal reclaimed water supply shall be deemed accessible where the supply is not greater than 150 percent of the distance that the potable water supply is from the lot boundary or the supply is within 100 feet (30.5 m) of a potable water supply that serves the lot.

**Reason:** This proposal relocates Section 702.7 (Municipal reclaimed water) from Section 702 (Fixtures, fittings, equipment and appliances) to Section 709 (Reclaimed water systems). It does not revise any of the language.

This proposal is intended to improve the organization and use of this chapter. Users are not likely to look for reclaim water requirements in Section 702; they will look in Section 709.

**Cost Impact:** Will not increase the cost of construction.

GEW158-14: 702.7-MEADOWS681

---