

GEW170-14

708.12

Proponent: Dru Meadows, The Green Team, Inc., representing Walmart
(dmeadows@thegreenteaminc.com)

Revise as follows:

708.12 Gray Specific gray water system design. The design of the gray water system shall conform to ~~accepted engineering practice~~the requirements of Section 708.

Reason: The term "accepted engineering practice" is subjective and difficult to enforce.

Cost Impact: Will not increase the cost of construction.

GEW 170-14: 708.12-MEADOWS241
