

GEW172-14

709.9

Proponent: Dru Meadows, The Green Team, Inc., representing Walmart
(dmeadows@thegreenteaminc.com)

Revise as follows:

709.9 Reclaimed water systems. The design of the reclaimed water systems shall conform to ASTM E 2635 and ~~accepted engineering practice~~ the requirements of Section 709.

Reason: The term "accepted engineering practice" is subjective and difficult to enforce.

Cost Impact: Will not increase the cost of construction.

GEW172-14: 709.9-MEADOWS680
