

GEW183-14

707.11.4

Proponent: Lisa Reiheld, Canadian Standards Association, representing CSA Group
(lisa.reiheld@csagroup.org)

Revise as follows:

707.11.4 Collection pipe materials. ~~In buildings where rainwater collection and conveyance systems are installed, drainage piping approved for use within plumbing drainage systems shall be utilized to collect rainwater and convey it to the storage tank. Vent piping approved for use within plumbing venting systems shall be utilized for all vents within the rainwater system. Drains to a storm water discharge shall use approved waste piping. Piping for conveying rainwater to a rainwater storage tank and from a rainwater storage tank overflow and drain to a point of discharge, shall be in accordance with Chapter 11 of the *International Plumbing Code*. Piping for venting rainwater storage tanks shall be in accordance with Section 702.1 of the *International Plumbing Code*. Rainwater conveyance systems, other than piping, shall be approved.~~

Reason: Adding the reference to those materials specified in the *International Plumbing Code* keeps this section consistent with all other sections that refer to approved products as those allowed by the IPC.

Cost Impact: Will not increase the cost of construction.

GEW183-14: 707.11.4-REIHELD1177
