

GEW51-14

603.5

Proponent: John Williams, CBO, Chair, representing ICC Adhoc Health Care Committee (AHC@iccsafe.org); Brenda Thompson, Chair, representing Sustainability, Energy, High Performance code Action Committee (SEHPCAC@iccsafe.org)

Revise as follows:

603.5 Minimum energy measurement and verification. Meters, sub-meters, and other *approved* devices installed in compliance with Sections 603.3 and 603.4 shall be connected to a data acquisition and management system capable of storing not less than 36-months worth of data collected by all meters and other *approved* devices and transferring the data in real time to a display as required in Section 603.6.

Exception: Stationary reciprocating internal combustion engines (RICE) provided for emergency and standby power are not required to be connected to a data acquisition and management system.

Reason: Certain stationary reciprocating internal combustion engines (RICE) are maintained in order to be able to respond to emergency power needs. The EPA allows exceptions for the emissions requirements for these generators as listed below in 40 CFR § 63.6640 Paragraph (f) and metering these for gross consumption and peak demand is an undue burden.

EPA § 63.6640 Paragraph (f) Requirements for emergency stationary RICE.

(1) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a new or reconstructed emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that was installed on or after June 12, 2006, or an existing emergency stationary RICE located at an area source of HAP emissions, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1)(i) through (iii) of this section. Any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1)(i) through (iii) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1)(i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines.

(i) There is no time limit on the use of emergency stationary RICE in emergency situations.

(ii) You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per year.

(iii) You may operate your emergency stationary RICE up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity; except that owners and operators may operate the emergency engine for a maximum of 15 hours per year as part of a demand response program if the regional transmission organization or equivalent balancing authority and transmission operator has determined there are emergency conditions that could lead to a potential electrical blackout, such as unusually low frequency, equipment overload, capacity or energy deficiency, or unacceptable voltage level. The engine may not be operated for more than 30 minutes prior to the time when the emergency condition is expected to occur, and the engine operation must be terminated immediately after the facility is notified that the emergency condition is no longer imminent. The 15 hours per year of demand response operation are counted as part of the 50 hours of operation per year provided for non-emergency situations. The supply of emergency power to another entity or entities pursuant to financial arrangement is not limited by this paragraph (f)(1)(iii), as long as the power provided by the financial arrangement is limited to emergency power.

(2) If you own or operate an emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions that was installed prior to June 12, 2006, you must operate the engine according to the conditions described in paragraphs (f)(2)(i) through (iii) of this section. If you do not operate the engine according to the requirements in paragraphs (f)(2)(i) through (iii) of this section, the engine will not be considered an emergency engine under this subpart and will need to meet all requirements for non-emergency engines.

(i) There is no time limit on the use of emergency stationary RICE in emergency situations.

(ii) You may operate your emergency stationary RICE for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by the manufacturer, the vendor, or the insurance company associated with the engine. Required testing of such units should be minimized, but there is no time limit on the use of emergency stationary RICE in emergency situations and for routine testing and maintenance.

(iii) You may operate your emergency stationary RICE for an additional 50 hours per year in non-emergency situations. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

This proposal is cosponsored by the ICC Ad Hoc Committee for Healthcare (AHC) and the ICC Sustainability Energy and High Performance Code Action Committee (SEHPCAC).

The AHC was established by the ICC Board of Directors to evaluate and assess contemporary code issues relating to hospitals and ambulatory healthcare facilities. The AHC is composed of building code officials, fire code officials, hospital facility engineers, and state healthcare enforcement representatives. The goals of the committee are to ensure that the ICC family of codes appropriately addresses the fire and life safety concerns of a highly specialized and rapidly evolving healthcare delivery system. This process is part of a joint effort between ICC and the American Society for Healthcare Engineering (ASHE), a subsidiary of the American Hospital Association, to eliminate duplication and conflicts in healthcare regulation. Since its inception in April, 2011, the AHC has held 11 open meetings and over 162 workgroup calls which included members of the AHC as well as any interested party to discuss and debate the proposed changes. All meeting materials and reports are posted on the AHC website at: <http://www.iccsafe.org/cs/AHC/Pages/default.aspx>.

The SEHPCAC was established by the ICC Board of Directors to pursue opportunities to improve and enhance International Codes with regard to sustainability, energy and high performance as it relates to the built environment included, but not limited to, how these criteria relate to the International Green Construction Code (IgCC) and the International Energy Conservation Code (IECC). This includes both the technical aspects of the codes as well as the code content in terms of scope and application of referenced standards. In 2012 and 2013, the SEHPCAC has held six two-day open meetings and 50 workgroup calls, which included members of the SEHPCAC as well as any interested parties, to discuss and debate proposed changes and public comments. Related documentation and reports are posted on the SEHPCAC website at: <http://www.iccsafe.org/cs/SEHPCAC/Pages/default.aspx>.

Cost Impact: Will not increase the cost of construction.

GEW51-14: 603.5-PAARLBERG437
