

GEW8-14

601.3.1

Proponent: Glenn Heinmiller, Lam Partners Inc., representing International Association of Lighting Designers (glenn@lampartners.com)

Revise as follows:

601.3.1 Performance-based compliance. Buildings designed on a performance basis shall comply with Sections 602, 608.6, 608.7, 608.8, 608.9, 609, 610 and 611.

Reason: The three items added by this proposal should be included in performance-based compliance calculations. 608.7 covers efficiency of transformers and electrical feeders, 608.8 includes fuel-gas lighting systems in energy calculations, and 608.9 expands the scope of exterior lighting efficiency provisions in the IGCC to include all site lighting, not just lighting that is powered through the building's electrical service. The performance path should not provide an exception from these basic efficiency requirements

Cost Impact: Will not increase the cost of construction.

GEW8-14: 601.3.1-HEINMILLER671
