

GG158-14

408.2.1

Proponent: Jason Thompson, Clark County Development Services, representing NCMA/MACS (jthompson@ncma.org)

Revise as follows:

408.2.1 Site hardscape materials. Hardscape materials shall have an initial solar reflectance value of not less than 0.30 in accordance with ASTM E 1918 or ASTM C 1549.

Exception: The following materials shall be deemed to comply with this section and need not be tested:

1. Pervious and permeable ~~concrete~~ pavements.
2. Concrete paving without added color or stain.

Reason: Pervious and permeable pavement systems are not limited solely to concrete pavements, but could include materials such as stone and clay-based materials and open grid pavers intended for pedestrian and light vehicular traffic. This modification captures the original intent of this exception by making it material independent.

Cost Impact: Will not increase the cost of construction.

GG158-14: 408.2.1 #2-THOMPSON874