

GG 216-14

506.3

Proponent: Lisa Reiheld, Canadian Standards Association, representing Canadian Standards Association Group (lisa.reiheld@csagroup.org)

Revise as follows:

506.3 Compact fluorescent lamps. Single-ended pin-base and screw-base compact fluorescent lamps shall contain not more than 5 milligrams of mercury per lamp, and shall be listed and labeled in accordance with CSA C861 or UL 1993.

Exception: Lamps rated at 25 watts or greater shall contain not more than 6 milligrams of mercury per lamp.

Add new standard(s) as follows:

CSA C861-10 Performance of self-ballasted compact fluorescent lamps and ballasted adapters.

Reason: Addition of compliance to CSA C861 "Performance of self-ballasted compact fluorescent lamps and ballasted adapters" is standard equivalent to UL 1993 "Self-Ballasted Lamps and Lamp Adapters" currently referenced.

Cost Impact: Will not increase the cost of construction.

Analysis: A review of the standard proposed for inclusion in the code, CSA C861-10 with regard to the ICC criteria for referenced standards (Section 3.6 of CP#28), will be posted on the ICC website on or before April 1, 2014.

GG216-14: 506.3-REIHELD1199