

## GG229-14

### 803.4

**Proponent:** Brenda Thompson, Clark County Development Services, Las Vegas, NV, representing SEHPCAC

**Revise as follows:**

**803.4 Isolation of pollutant sources.** The isolation of pollutant sources related to print, copy and janitorial rooms, ~~garages and hangars~~ shall be in accordance with Section 803.4.1.

**Reason:** Section 803.4 refers to Section 803.4.1 for requirements related to “garages and hangars.” There are no requirements, however, for garages and hangars in Section 803.4.1. This language is a remnant from past editions of the code and is no longer relevant.

This proposal was submitted by the ICC Sustainability Energy and High Performance Code Action Committee (SEHPCAC). The SEHPCAC was established by the ICC Board of Directors to pursue opportunities to improve and enhance International Codes with regard to sustainability, energy and high performance as it relates to the built environment included, but not limited to, how these criteria relate to the International Green Construction Code (IgCC) and the International Energy Conservation Code (IECC). This includes both the technical aspects of the codes as well as the code content in terms of scope and application of referenced standards. In 2012 and 2013, the SEHPCAC has held six two-day open meetings and 50 workgroup calls, which included members of the SEHPCAC as well as any interested parties, to discuss and debate proposed changes and public comments. Related documentation and reports are posted on the SEHPCAC website at: <http://www.iccsafe.org/cs/SEHPCAC/Pages/default.aspx>.

**Cost Impact:** Will not increase the cost of construction

GG229-14 : 803.4-THOMPSON353

---