

**WISCONSIN CLASS B UST SYSTEM OPERATOR
CONTENT OUTLINE**

60 Questions, 2 hours, Open Book

Approximate % of 60 Questions

01 UST Systems **17%**

0101 Tanks, Piping, Containment and Monitoring Systems
Identify type, size, material and contents of tank. Identify the type and placement of monitoring systems. Identify piping, type and material, pressure / suction piping. Determine if the UST system has secondary containment.

0102 Operation Authority
Determine laws and regulations under which the facility is operated. Determine laws and regulations applicable to temporary and permanent closure. Verify compliance with applicable local, state laws.

02 Operating Requirements **18%**

0201 Overfill and Spill Protection
Verify that overfill protection and spill prevention devices present & operational.

0202 Corrosion Protection
Verify that the cathodic protection system is operational and that cathodic protection testing is performed at required intervals.

0203 Inspections, and Emergency Equipment
Verify that sumps and spill containment boxes are inspected for accumulation of liquid and debris. Inspect hardware such as nozzles, breakaway couplings, hoses and impact valves. Verify emergency equipment shut-off, fire extinguishers & fire suppression systems & alarm pull boxes in place & operational.

0204 Good Housekeeping
Determine the proper way to clean up and handle product spills, overflow from a tank or customer container.

03 Release Detection **15%**

0301 Release Detection & Release Detection Equipment
Verify correct method of release detection is in place & implemented properly and at the required frequency. Verify that any leak detection devices and equipment are operational and have third party certification if applicable.

0302 Release Detection Testing
Verify that all required periodic testing & maintenance is performed.

04 Recordkeeping **15%**

0401 Release Detection Record Keeping
Maintain written performance claims, results of sampling, testing monitoring, written documentation of calibration, maintenance & repair.

0402 General Operating Recordkeeping and Reporting
Maintain records of the operation and testing of the corrosion protection, and vapor recovery systems.

0403 Registration, Installation, Upgrade, Repair and Closure Records
Maintain records of all installation, upgrade, repairs and closures.

0404 Financial Responsibility
Maintain financial responsibility.

05 Release Reporting and Confirmation**8%****0501** Reporting of Suspected Release

Report releases as required to the implementing agency within the required time frame. Maintain records of releases.

0502 Reporting and Cleanup of Spills and Overfills

Contain and immediately clean up a spill or overfill and report such to the implementing agency within the required time.

06 Energy Act Requirements**27%****0601** Performance Standards for USTs

Identify the secondary containment requirements for tanks, lines and dispensers

0602 Delivery Prohibition

Implement criteria for red tag mechanisms used to identify ineligible USTs

0603 Operator Training

Design UST training to ensure knowledge regarding operating and maintaining systems