Certification: Commercial Electrical Inspector

Exam ID: E2

- 80 multiple-choice questions
- 3-1/2-hour limit
- Open book



01 General Requirements

10%

3%

0101 Project Administration and Legal

Verify that required permits are issued and valid. Issue and maintains inspection reports, correction notices, stop work orders, and data for the issuance of the certificate of occupancy. Verify that the required approved plans and specifications are available on the job site. (Some

questions may refer to a set of plans for reading fixture schedules, panel schedules, riser diagrams,

0102 Public Information

2%

Communicate the intent of the code using proper terminology. Answer questions about general code compliance, procedures, and materials. Identify the suitability of the installation of materials according to the listing, and labeling.

0103 Conductors

5%

Inspect conductors to verify correct use and installation, type, insulations, markings, and ampacity. Verify that conductor connections, splices, and terminal identification meet code requirements.

02 Services

17%

0201 Service Size, Rating, and Installations

8%

Inspect services to verify, required conductor ampacity, clearances, location, materials, equipment, and provisions for installation.

0202 Service and Feeder Grounding and Bonding

9%

Verify size, type of conductors, and electrodes, including location and installation.

03 Branch Circuit and Feeder Requirements

19%

0301 Branch Circuit and Feeder Installation

5%

Inspect branch circuit and feeder installation to verify conductor size, clearances, location, materials, and equipment grounding conductors.

0302 <u>Branch Circuit and Feeder Calculations</u>

4%

Verify that the load to be placed on branch circuits and feeders meets code provisions for the conductor, devices, materials, and equipment installed.

0303 Branch Circuit Ratings and Overcurrent Protection

5%

Verify correct size, type, location, and installation of overcurrent devices.

0304	Equipment Grounding and Bonding Verify correct size, type, location, and installation requirements for equipment grounding.	5%
04	Wiring Methods and Distribution Systems	19%
0401	Branch Circuit Required Outlets Verify that receptacle and lighting outlets and switches are provided in all required locations. Verify that ground-fault circuit interrupter protection is provided in all required locations.	3%
0402	Boxes, Enclosures, and Conduit Bodies Verify that boxes, enclosures, and conduit bodies are proper type and correctly sized and installed.	5%
0403	<u>Panelboards and Switchboards</u> Verify location, clearances, rating, circuit identification, and overcurrent protection.	6%
0404	Raceways, Cables, and Bus Ducts Inspect conduit raceways, wireways, busways, and cable bus to verify correct use, type, size, support, and installation. Inspect sheathed cable, armored cable, metal-clad cable, to verify correct use, type, support, and installation.	3%
0405	Flexible Cords and Fixture Wires Verify proper use and sizing of flexible cords.	2%
05	General Use Equipment	12%
0501	Switches, Receptacles, and Light Fixtures Verify that light fixtures and fixture wires are of correct type and rating, and are properly installed Verify that switches and receptacles are of the correct type and rating, and are installed properly.	3%
0502	General Use Equipment and Other Appliances Inspect general use equipment, space heating, and cooling equipment, including air conditioning and refrigeration wiring and equipment, to verify correct type, use, installation, and disconnecting means. Inspect appliance wiring and equipment to verify correct type, use, installation, and disconnecting means.	3%
0503	Motors and Controllers Inspect motors and phase converters to verify correct use, size, voltage, and type, and inspect motor control circuits to verify correct size, motor protection when required, and wiring.	3%
0504	<u>Transformers, Generators, and Miscellaneous Equipment</u> Inspect other general use equipment and wiring, including capacitors, resistors, and batteries, to	3%

06	Special Occupancies	9%
0601	Hazardous Locations Inspect materials and equipment required specifically for use in hazardous locations to verify suitability for the intended use, and verify that work is correctly installed and sealed.	3%
0602	Health Care Facilities Inspect electrical installations in health care facilities to verify compliance with special code requirements.	2%
0603	Miscellaneous Other Special Occupancies Inspect the electrical installations of other special occupancies to verify compliance with special code requirements.	1%
0604	Commercial Garages, Gas Stations, and Bulk Stations Verify correct type of wring methods and materials for commercial garages, gas stations, and bulk stations, and similar hazardous locations.	3%
07	Special Equipment	7%
0701	Swimming Pools, Fountains, and Similar Installations Inspect electric wiring and equipment installed for swimming pools, spas, indoor installations of decorative fountains, and similar installations to verify correct type, use, bonding, and installation of electrical materials.	4%
0702	Miscellaneous Special Equipment Inspect electric wiring and equipment for miscellaneous special equipment to verify correct type, use, and installation. Verify correct wiring for computer and data equipment. Inspect electric wiring and equipment installed for electric signs to verify correct type, use, and installation.	3%
08	Special Systems	7%
0801	Emergency Systems Inspect emergency system wiring, including legally required and optional standby systems.	2%
0802	Signaling Systems Inspect low voltage control wiring, Class 1, 2, and 3 circuits; and fire protective signaling circuits.	2%
0803	Fire Alarm Systems Inspect fire alarm systems for correct use, wire size, type, installation, and operation. Verify correct location, number, and wiring of fire alarm system devices.	2%
0804	<u>Communications Systems</u> Verify proper type and location of wire installed for communication circuits, including CATV and fiber optics. Verify proper clearances and grounding of conductors for communications systems.	1%