

2012 International Mechanical Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (Posted: 02-27-13)

CHAPTER 4 VENTILATION

401.2 Ventilation required. Every occupied space shall be ventilated by natural means in accordance with Section 402 or by mechanical means in accordance with Section 403. Where the air infiltration rate in a dwelling unit is less than 5 air changes per hour when tested with a blower door at a pressure of 0.2-inch water column (50 Pa) in accordance with Section R402.4.1.2 of the *International Energy Conservation Code*, the dwelling unit shall be ventilated by mechanical means in accordance with Section 403.

401.4 Intake opening location. Air intake openings shall comply with all of the following:

2. Mechanical and gravity outdoor air intake openings shall be located not less than 10 feet (3048 mm) horizontally from any hazardous or noxious contaminant source, such as vents, streets, alleys, parking lots and loading docks, except as specified in Item 3 or Section ~~504.2.4~~ 501.3.1. Outdoor air intake openings shall be permitted to be located less than 10 feet (3048 mm) horizontally from streets, alleys, parking lots and loading docks provided that the openings are located not less than 25 feet (7620 mm) vertically above such locations. Where openings front on a street or public way, the distance shall be measured from the closest edge of the street or public way.

**TABLE 403.3
MINIMUM VENTILATION RATES**

OCCUPANCY CLASSIFICATION	OCCUPANT DENSITY #/1000 FT ² a	PEOPLE OUTDOOR AIRFLOW RATE IN BREATHING ZONE, R _p CFM/PERSON	AREA OUTDOOR AIRFLOW RATE IN BREATHING ZONE, R _a CFM/FT ² a	EXHAUST AIRFLOW RATE CFM/FT ² a
Hotels, motels, resorts and dormitories				
Multipurpose assembly	<u>120</u>	5	0.06	—
Bathrooms/toilet—private ⁹		—	—	25/50f
Bedroom/living room	<u>10</u>	5	0.06	—
Conference/meeting	<u>50</u>	5	0.06	—
Dormitory sleeping areas	<u>20</u>	5	0.06	—
Gambling casinos	<u>120</u>	7.5	0.18	—
Lobbies/prefunction	<u>30</u>	7.5	0.06	—

2012 International Mechanical Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (Posted: 02-27-13)

CHAPTER 5 EXHAUST SYSTEMS

[F] 502.4 Stationary storage battery systems. Stationary storage battery systems, as regulated by Section 608 of the *International Fire Code*, shall be provided with ventilation in accordance with this chapter and Section 502.4.1 or 502.4.2.

Exception: Lithium-ion and lithium metal polymer batteries shall not require additional ventilation beyond that which would normally be required for human occupancy of the space.

506.3.11 Grease duct enclosures. A grease duct serving a Type I hood that penetrates a ceiling, wall, floor or any concealed spaces shall be enclosed from the point of penetration to the outlet terminal. A duct shall penetrate exterior walls only at locations where unprotected openings are permitted by the *International Building Code*. The duct enclosure shall serve a single grease duct and shall not contain other ducts, piping or wiring systems. Duct enclosures shall be either field-applied or factory-built. Duct enclosures shall have a fire-resistance rating of not less than that of the assembly penetrated and not less than 1 hour. Duct enclosures shall be as prescribed by Section ~~506.3.10.4~~ 506.11.1, ~~506.3.10.2~~ 506.11.2 or ~~506.3.10.3~~ 506.11.3.

506.3.11.2 Field-applied grease duct enclosure. Commercial kitchen grease ducts constructed in accordance with Section 506.3.1 shall be enclosed by field-applied grease duct enclosure that is a listed and labeled material, system, product, or method of construction specifically evaluated for such purpose in accordance with ASTM E 2336.

The surface of the duct shall be continuously covered on all sides from the point at which the duct originates to the outlet terminal. Duct penetrations shall be protected with a through-penetration fire-stop system classified in accordance with ASTM E 814 or UL ~~1497~~ 1479 and having a "F" and "T" rating equal to the fire-resistance rating of the assembly being penetrated. Such systems shall be installed in accordance with the listing and the manufacturer's installation instructions. Partial application of a field-applied grease duct enclosure system shall not be installed for the sole purpose of reducing clearances to combustibles at isolated sections of grease duct. Exposed duct-wrap systems shall be protected where subject to physical damage.

506.5.5 Termination location. The outlet of exhaust *equipment* serving Type I hoods shall be in accordance with Section ~~506.3.42~~ 506.3.13.

[F] 513.12.3 Automatic control. Where completely automatic control is required or used, the automatic control sequences shall be initiated from an appropriately zoned automatic sprinkler system complying with Section 903.3.1.1 of the *International Fire Code*, ~~or~~ from manual controls that are readily accessible to the fire department, and any smoke detectors required by engineering analysis.

2012 International Mechanical Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (Posted: 02-27-13)

CHAPTER 11 REFRIGERATION

1105.6.3 Ventilation rate. For other than ammonia systems, the mechanical ventilation systems shall be capable of exhausting the minimum quantity of air both at normal operating and emergency conditions, as required by Sections 1105.6.3.1 and 1105.6.3.2. The minimum required ventilation rate for ammonia shall be 30 air changes per hour in accordance with IIAR2. Multiple fans or multispeed fans shall be allowed to produce the emergency ventilation rate and to obtain a reduced airflow for normal ventilation.

1109.1 Testing required. The following emergency devices and systems shall be periodically tested in accordance with the manufacturer's instructions and as required by the code official:

1. Treatment and flaring systems.
2. Valves and appurtenances necessary to the operation of emergency refrigeration control boxes.
3. Fans and associated *equipment* intended to operate emergency ~~pure~~ ventilation systems.
4. Detection and alarm systems.

2012 INTERNATIONAL MECHANICAL CODE
ERRATA

1st PRINTING (Updated May 24, 2011)

CHAPTER 11
REFRIGERATION

1105.6.3 Ventilation rate. For other than ammonia systems, the mechanical ventilation systems shall be capable of exhausting the minimum quantity of air both at normal operating and emergency conditions, as required by Sections 1105.6.3.1 and 1105.6.3.2. The minimum required ventilation rate for ammonia shall be 30 air changes per hour in accordance with IAR2. Multiple fans or multispeed fans shall be allowed to produce the emergency ventilation rate and to obtain a reduced airflow for normal ventilation.

2012 International Mechanical Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (Posted: 02-27-13)

CHAPTER 15 REFERENCED STANDARDS

Chapter 15 (footers should read “2012 International Mechanical Code”)