

**ICC 500-2014 Errata
List
Posted: 8/2023**

**CHAPTER 3
STRUCTURAL DESIGN CRITERIA**

304.6 Enclosure classifications. Enclosure classifications for storm shelters shall be determined in accordance with ASCE 7, Section ~~6-2~~ 26.2. For determining the enclosure classification for community storm shelters, the largest door or window on a wall that receives positive external pressure shall be considered as an opening.

**Chapter 4
SITING**

401.2 Design criteria. Storm shelters or portions thereof subject to flooding shall be designed in accordance with the provisions of this chapter, ASCE 7, ~~Section Chapter~~ 5 and ASCE 24.

**Chapter 9
REFERENCED STANDARDS**

ASTM

~~C920—08 Standard Specification for Elastomeric Joint Sealants ...306.8~~

Note: The reference to this standard was deleted in from the 2008 edition Section 306.3.2. It is not referenced in the 2014 edition, so this is an erratum and will be deleted.

~~E1996—12 Specification for Performance of Exterior Windows, Curtains Walls, Doors and Impact Protective Systems Impacted by Windborne Debris in Hurricane306.3.2~~

TMS

The Masonry Society
105 South Sunset Street, Suite Q
Longmont, CO 80501

602—2011 Specification for Masonry Structures... 306.8