

ICC 300-2017 errata
STANDARD FOR BLEACHERS, FOLDING AND TELESCOPIC SEATING,
AND GRANDSTANDS

Posted Feb. 7, 2022

Page 6:

SECTION 309
FIRE PROTECTION

309.1 Fire protection. Fire protection systems shall be provided where required by the building code.

Exceptions:

1. An emergency voice/alarm system is not required for outdoor bleacher-type seating provided all of the following are met:
 - 1.1. The bleacher-type seating has an occupant load of less than 15,000;
 - 1.2. A public address system with standby power is provided;
 - 1.3. Enclosed spaces attached or immediately adjacent to the bleacher-type seating comprise, in the aggregate, 10 percent or less of the overall area of the bleacher-type seating or 1,000 square feet (92.9 m²), whichever is less.
 - 1.4. Spaces under the bleacher-type seating shall be separated from the bleacher-type seating in accordance with ~~Section 4029.8.4.1.4~~ 1029.1.1.1 of the *International Building Code*.
 - 1.5. All means of egress from the bleacher-type seating are open to the outside.
2. An emergency voice/alarm system is not required for outdoor bleacher-type seating with an occupant load of 300 or less.
3. An emergency voice/alarm system is not required for temporary outdoor bleacher-type seating providing all of the following are met:
 - 3.1. There are no enclosed spaces under or attached to the bleacher-type seating;
 - 3.2. The bleacher-type seating is erected for a period of less than 180 days;
 - 3.2. Evacuation of the bleacher-type seating is included in an approved fire safety plan.