



# International Code Council

(Committee approved 6/10/21)

## FOURTH COMMITTEE MEETING MINUTES ICC CONSENSUS COMMITTEE ON LOG STRUCTURES (IS-LOG)

The fourth teleconference meeting of the ICC Committee on Log Structures (IS-LOG) was convened on May 27, 2021 to continue the process of developing the next edition of the ICC 400 standard.

1. Meeting Opening

- a. Opening remarks, objective of the meeting, and housekeeping:

*Director of Standards and Staff Secretariat, Karl Aittaniemi called the meeting to order at 1:02 PM CT on May 27, 2021 and welcomed all committee members and Interested Parties. Mr. Aittaniemi noted that the meeting was public in accordance with ICC policy. All meeting participants were urged to read the ICC Code of Ethics and section 5.1.10 Representation of Interests in Council Policy #7 in the spirit of code of conduct. These documents are on ICC’s website under Corporate Governance.*

- b. Quorum and membership review:

*Mr. Aittaniemi called the roll of the IS-LOG with the following members registering attendance. Mr. Aittaniemi noted that 5 of 9 committee members is required for a quorum in order to conduct business which was exceeded for the meeting.*

NAME	2021 IS-LOG COMMITTEE MEETING			
	#1 3/4/21	#2 3/18/21	#3 4/1/21	#4 5/27/21
Robert Chambers [D]	X	X	X	
David Conner [C]	X	X	X	X
Robert Kenel [B]	X	X	X	X
William McKinney [H]	X	X	X	
Jonathon Paradine [H]	X	X	X	X
Rob Pickett [A]		X	X	X
Loren Ross [C]	X	X	X	X
Donald Sivigny [H]	X	X	X	X
Fred Roberts [I]			X	X
<b>TOTAL</b>	8/9	8/9	9/9	7/9

2. Jason Toves with ICC's Technical Services addressed the committee regarding a re-occurring issue with staff opinion requests and Section 305.3.1.1 of the ICC 400-2017. After committee discussion, Mr. Ross suggested the following:

**305.3.1.1 U-Factor.** The U-Factor ( $U_w$ ) of the opaque log wall assembly shall be selected from Table 305.3.1.1 to meet the Mass Wall U-Factor requirements of Table R402.1.2 or C402.1.3 of the IECC as applicable.

*Committee discussion will continue on this subject for the next meeting.*

3. With no public comments yet received during the current ANSI public review period, Mr. Aittaniemi updated the committee on progress:

- *The deadline to receive public comments is June 7, 2021 close of business.*
- *There were no additional comments from the proponents in the committee action report at the May 5, 2021 deadline therefore committee action is considered to have resolved all the initial public comments.*
- *ICC staff has begun the process to seek permission from ASHRAE for use of the Figure 304.2.2.3 CLIMATE ZONE MAP.*
- *There has been some thoughts on bringing IECC Table R301.1 Climate Zones, Moisture Regimes and Warm-Humid Designations by State, County and Territory into ICC400 as Appendix A.*

4. Next Meeting:

*The next meetings are to be scheduled for June 10, 2021, 2 PM ET and June 17, 2021, 2 PM ET.*

5. Other Business: *None*

6. Adjournment

*With no other questions or comments before the committee Mr. Pickett adjourned the meeting at 1:50 PM CT.*