



ICC 1125-202X edition

First Committee Action Report on initial draft edition of the ICC 1125 Standard

For Committee Actions taken on the Public Input of the Initial Draft (posted on November 25, 2024), with comments received through January 27, 2025.

The public meetings were held via Teams from March 14, 2025 through May 23, 2025.

Matrix for ICC 1125 committee action

Proposal #	Section Number	Date of meeting proposal considered	Committee Action	Notes
Chapter 1 APPLICATION AND ADMINISTRATION				
ICC 1125 IS-MGOB GA Com 11	101.1	4/25/25	No action taken	Testing: Subgroup modified section by adding, “building an,” due to Keith Nelson Comment 1. The commentor agreed.
ICC 1125 IS-MGOB Keith Nelson Com 1	101.1	4/25/25	Approved as modified	Improved and more accurate language: Subgroup modified section by adding, “building an.” The commentor agreed.
ICC 1125 IS-MGOB Keith Nelson Com 2	101.2	4/25/25	Approved as modified	Improved and more accurate language: Changes made based on comment.
ICC 1125 IS-MGOB Keith Nelson Com 3	101.3	4/25/25	Approved as modified	Improved and more accurate language: Changes made based on comment.
Chapter 2 DEFINITIONS				
ICC 1125 IS-MGOB GA Com 12	202	4/25/25	No change made	“Exterior Wall”: After discussion with the commentor, no change was made. The commentor agreed.
ICC 1125 IS-MGOB GA Com 13	202	4/25/25	Approved as modified	“Fiber-reinforced Magnesium-oxide-based Sheets”: Changes made to the definition. The commentor agreed.
ICC 1125 IS-MGOB GA Com 15	202	4/25/25	Approved as modified	“Compression indentation”: Commentor agreed with leaving the exception and the word “use” was relocated within the definition.
ICC 1125 IS-MGOB GA Com 16	202	4/25/25	No change made	“Falling-ball impact”: Commentor agreed that the definition is okay with standard reference.
ICC 1125 IS-MGOB GA Com 9 and GA Com 14	202	4/25/25	Approved as modified	“Wet areas”: Subgroup deleted two definitions of “Wet Areas” and kept the third definition.
ICC 1125 IS-MGOB NXGN Com 1	202		Approved as modified	Corrected Table reference and numerical corrections from draft.

2025 ICC 1125 – First Committee Action Report

Proposal #	Section Number	Date of meeting proposal considered	Committee Action	Notes
ICC 1125 IS-MGOB NXGN Com 2	202	3/14/25	Approved as modified	“Fiber-reinforced Magnesium-oxide-based Sheets”: Modified definition to address thickness issue based on commentors recommendation.
ICC 1125 IS-MGOB NXGN Com 3	202	3/14/25	Approved as modified	“Proprietary nails”: Modified table references based on commentors recommendation.
ICC 1125 IS-MGOB NXGN Com 4	202	3/14/25	Approved as modified	“Nails, Stainless Steel”: Reference section changed to Section 6.2 of ASTM F1667.
ICC 1125 IS-MGOB GA Com 10	202	3/25/25	Approved as modified	“Engineered Wood”: The work group agreed with the comment. The definition was deleted.
ICC 1125 IS-MGOB Keith Nelson Com 4	202	4/25/25	Approve as modified	“Fiber-reinforced Magnesium-oxide based boards”: Definition made.
ICC 1125 IS-MGOB Keith Nelson Com 5	202	4/25/25	No action taken	“Wet Areas”: Withdrawn based on GA comments 9 and 14 action.
Chapter 3 REQUIREMENTS FOR ALL USE TYPES				
ICC 1125 IS-MGOB GA Com 4	301.1	4/11/25	No change	ASTM C666 reference: The commentor and the subgroup agreed to leave the last published version in the standard.
ICC 1125 IS-MGOB NXGN Com 6	301.1	3/14/25	Approved as modified	ASTM 1185 and 1186 references: Changes made to dimensions and tolerances.
ICC 1125 IS-MGOB USG Comment	Table 301.1	4/25/25	Approved as modified	Minimum Physical Properties: Subgroup added Section 301.1.2 based on comment.
ICC 1125 IS-MGOB NXGN Com 5	301.1.1	3/14/25	Approved as modified	Accepted the changes regarding evidence of durability performance based on the commentors recommendation.
ICC 1125 IS-MGOB GA Com 5	301.1.1	4/11/25	No change	Standards versions cited: The commentor agreed to leave the years of the standards as shown in the initial draft.

2025 ICC 1125 – First Committee Action Report

Proposal #	Section Number	Date of meeting proposal considered	Committee Action	Notes
ICC 1125 IS-MGOB USG Comment	301.1.1	4/25/25	No change made	Minimum Physical Properties: Commentor agreed that existing Section 301.1.1 text addressed concern.
ICC 1125 IS-MGOB NXGN Com 7	302.7	3/14/25	Approved as modified	The exception was editorially changed.
ICC 1125 IS-MGOB GA Com 8	302.13	4/25/25	Approved as modified	Section reference: Section 302.13 modifications for the clarification of test period based on GA Comment 8. The commentor agreed to the modifications.
ICC 1125 IS-MGOB Keith Nelson Com 6	302.13	4/25/25	No action taken	Extended duration surface burning characteristics option: Withdrawn based on GA comment 8 action.
ICC 1125 IS-MGOB GA Com 7	302.14	4/11/25	Approved as modified	FRTW alternative objection: The subgroup deleted the section.
ICC 1125 IS-MGOB Keith Nelson Com 7	302.14	4/25/25	Approved as modified	FRTW alternative objection: The subgroup deleted the section. Note that action taken agrees with previous GA Com 7 action.
ICC 1125 IS-MGOB GA Com 17	302.15	4/25/25	Approved as modified	Fire-resistance-rated construction: UL 263 added to section. Commentor agreed with change.
ICC 1125 IS-MGOB Keith Nelson Com 8	302.15	4/25/25	No Action taken	Fire-resistance-rated construction: Withdrawn based on GA Com 17 action.
ICC 1125 IS-MGOB Keith Nelson Com 9	302.16	4/25/25	Approve as modified	Section deletion: Subgroup agreed and deleted section.
ICC 1125 IS-MGOB Keith Nelson Com 10	302.17	4/25/25	Approved as modified	Language improvement and correlation with IBC: Subgroup agreed with commentor. Changes were made to section.
ICC 1125 IS-MGOB Keith Nelson Com 12	302.17	4/25/25	Approved as modified	Labeling requirements: Subgroup agreed with commentor. Section 901.2 added and additional changes made to Chapter 9.
ICC 1125 IS-MGOB GA Com 18	302.19.4.1	4/25/25	No change made	Subsection reference of a standard: Commentor agreed with not making a change.

2025 ICC 1125 – First Committee Action Report

Proposal #	Section Number	Date of meeting proposal considered	Committee Action	Notes
ICC 1125 IS-MGOB Keith Nelson Com 11	302.19.5 and Table 302.19	4/25/25	Approved as modified	Language improvement and correlation between section and referenced table: Subgroup agreed with commentor. Changes were made to section.
ICC 1125 IS-MGOB NXGN Com 8	302.15	3/14/25	Approved as modified	Addition of UL 263
ICC 1125 IS-MGOB NXGN Com 9	302.16	3/14/25	Tabled due to other comments	Removal of height criterion
ICC 1125 IS-MGOB NXGN Com 10	302.18	3/14/25	Approved as modified	Change resistance value to growth rating: Subgroup changed term “mold” to “fungi”.
Chapter 4 WALL SHEATHING				
ICC 1125 IS-MGOB NXGN Com 11	402.2	4/25/25	Approved as modified	Repetitive language in Section 302.16 and 302.17 and Chapter 4: The subgroup accepted the comment.
ICC 1125 IS-MGOB GA Com 6	402.2	4/25/25	No change made	Section overrides code: Resolved with NXGN Com 11 action.
ICC 1125 IS-MGOB NXGN Com 12	402.3	4/25/25	Approved as modified	General cleanup: Subgroup agreed with comment.
ICC 1125 IS-MGOB GA Com 19	402.3	4/25/25	No change made	Dry areas and wet areas inconsistency: Resolved with NXGN Com 12 action.
ICC 1125 IS-MGOB NXGN Com 13	402.3.1	4/25/25	Approved as modified	General cleanup: Subgroup agreed with comment with editorial fixes.
ICC 1125 IS-MGOB NXGN Com 14	402.3.2	4/25/25	Approved as modified	Follow-up inspections, documentation and other issues: Subgroup accepted the comment with some modifications. Commentor agreed with final language.
ICC 1125 IS-MGOB GA Com 20	402.3.2	4/25/25	No Change made	Properties and characteristics of reinforcing fabrics, coatings, etc: Withdrawn by commentor based on Section 403 (Listing and labeling).
ICC 1125 IS-MGOB NXGN Com 15	402.3.3	4/25/25	Approved as modified	Clarification needed: Subgroup accepted the comment.

2025 ICC 1125 – First Committee Action Report

Proposal #	Section Number	Date of meeting proposal considered	Committee Action	Notes
ICC 1125 IS-MGOB GA Com 22	402.3.2.4.2.1	4/25/25	Editorially modified	Section 402.3.4.2.1 has the word “bad” which should probably be “load.”: Subgroup agreed and editorial change made.
ICC 1125 IS-MGOB NXGN Com 16	402.3.4.2.3.1	4/25/25	Approved as modified	Safety factor change: The subgroup agreed with the comment.
ICC 1125 IS-MGOB NXGN Com 17	402.3.5	4/25/25	Approved as modified	Installation Instructions: The subgroup agreed with the comment. Section 402.3.5 deleted and Section 403 (Listing and labeling) added.
ICC 1125 IS-MGOB NXGN Com 18	402.4.4	4/25/25	Approved as modified	Safety factor: The subgroup agreed with the comment with some modifications. The commentator agreed with the changes.
ICC 1125 IS-MGOB NXGN Com 19	402.5	4/25/25	Approved as modified	Testing and performance requirements: The subgroup agreed with comment.
ICC 1125 IS-MGOB GA Com 23	402.6		No action required	Section self-reference: Editorial comment incorporated in GA COM 24 action.
ICC 1125 IS-MGOB GA Com 23	402.6	4/25/25	No action required	Section self-reference: Editorial comment incorporated in GA COM 24 action.
ICC 1125 IS-MGOB GA Com 24	402.6	4/25/25	Standards review approved	Incomplete list of standards: Resolved with agreement that the standards would be reviewed and changes made as needed.
ICC 1125 IS-MGOB NXGN Com 20	402.6	4/25/25	Approved as modified	Follow-up inspections, documentation and other issues: Subgroup made changes to Section 402.6 and added Section 403 (Listing and labeling).
ICC 1125 IS-MGOB NXGN Com 21	402.6.3.1.2.1	4/25/25	Approved as modified	Proprietary fastener adjustment factor: Subgroup agreed with comment and incorporated recommendations.
ICC 1125 IS-MGOB NXGN Com 22	402.6.3.2.3	4/25/25	Approved as modified	Grammatical error and enforcement: Subgroup agreed with comment and incorporated the recommendations.

2025 ICC 1125 – First Committee Action Report

Proposal #	Section Number	Date of meeting proposal considered	Committee Action	Notes
ICC 1125 IS-MGOB NXGN Com 23	402.6.3.2.3.3.2	4/25/25	Approved as modified	Wall type reference: Subgroup agreed with comment and incorporated the recommendations.
ICC 1125 IS-MGOB NXGN Com 24	402.6.3.2.3.4	4/25/25	Approved as modified	Use of a “suitable engineering evaluation”: Resolved comment with the addition of Section 403 (Listing and labeling) and minor modifications. The commentor agreed.
ICC 1125 IS-MGOB NXGN Com 25	402.6.4	4/25/25	Approve as modified	Section deletion: Subgroup agreed with commentor. Section deleted and Section 403 (Listing and labeling) added.
Chapter 5 TILE BACKER				
ICC 1125 IS-MGOB NXGN Com 26	503.2.1	3/14/25	Approved as modified	Accepted the changes based on the commentors recommendations.
Chapter 6 RESERVED				
Chapter 7 STRUCTURAL FLOOR SHEATHING ATTACHED TO COLD-FORMED STEEL OR WOOD FRAMING				
ICC 1125 IS-MGOB NXGN Com 28	702.4	3/28/25	Approved as modified	Sentence removal for allowable uniform load for spans shorter than tested.
ICC 1125 IS-MGOB NXGN Com 27	702.3.1	3/14/25	Approved as modified	Spans Greater than 24 inches: Spans larger than 24 inches provision removed.
ICC 1125 IS-MGOB NXGN Com 29	702.5.1	3/28/25	Approved as modified	Removal of evaluation report requirement.
ICC 1125 IS-MGOB NXGN Com 30	702.5.2	3/28/25	Approved	No changes made or required.
ICC 1125 IS-MGOB NXGN Com 31	703.1.1	3/28/25	Approved as modified	Remove reference to fiber cement, correct section references, deletion of last section.
ICC 1125 IS-MGOB NXGN Com 32	703.1.2	3/28/25	Approved as modified	Remove reference to fiber cement, correct section reference.
ICC 1125 IS-MGOB NXGN Com 33	703.1.4	3/28/25	Approved as modified	Resolved with commentor to leave language and add clarifying language.

2025 ICC 1125 – First Committee Action Report

Proposal #	Section Number	Date of meeting proposal considered	Committee Action	Notes
ICC 1125 IS-MGOB NXGN Com 34	703.1.4.2	3/28/25	Approved as modified	Remove evaluation report language and correct section references.
ICC 1125 IS-MGOB NXGN Com 35	703.1.4.3	3/28/25	Approved as modified	Delete steel plate items and correct section references.
ICC 1125 IS-MGOB NXGN Com 36	703.1.4.4	3/28/25	Approved as modified	Removal of steel plate references.
ICC 1125 IS-MGOB NXGN Com 37	703.1.5	3/28/25	Approved as modified	Remove reference to fiber cement and correct section references.
Chapter 8 STRUCTURAL ROOF SHEATHING ATTACHED TO COLD-FORMED STEEL OR WOOD FRAMING				
ICC 1125 IS-MGOB NXGN Com 38	802.1	3/28/25	Approved as modified	Remove structural cementitious panel reference and correct reference location items.
ICC 1125 IS-MGOB NXGN Com 39	802.1.2.12.1	3/28/25	Approved as modified	Changed language from third party to listing.
ICC 1125 IS-MGOB NXGN Com 40	802.1.2.12.2	3/28/25	Approved as modified	Changed language from third party to listing.
ICC 1125 IS-MGOB NXGN Com 41	803.1.1	3/28/25	Approved as modified	Remove fiber cement reference and deletion of last section.
ICC 1125 IS-MGOB NXGN Com 42	803.1.2	3/28/25	Approved as modified	Accepted the changes based on the commentors recommendations.
ICC 1125 IS-MGOB NXGN Com 43	803.1.4	3/28/25	Approved as modified	Addressed commentor's language and addressed changes to section with agreement of subgroup.
ICC 1125 IS-MGOB NXGN Com 44	803.1.4.1	3/28/25	Approved as modified	Additional table added and removed previous version.
ICC 1125 IS-MGOB NXGN Com 45	803.1.4.2	3/28/25	Approved as modified	Corrected evaluation to listing.
ICC 1125 IS-MGOB NXGN Com 46	803.1.4.3	3/28/25	Approved as modified	Accepted the changes based on the commentors recommendations.
ICC 1125 IS-MGOB NXGN Com 47	803.1.4.4	3/28/25	Approved as modified	Removal of steel plate references, corrected reference locations.
ICC 1125 IS-MGOB NXGN Com 48	803.1.5	3/28/25	Approved as modified	Removed reference to fiber cement and changes made based upon comments.

2025 ICC 1125 – First Committee Action Report

Proposal #	Section Number	Date of meeting proposal considered	Committee Action	Notes
Chapter 9 IDENTIFICATION				
ICC 1125 IS-MGOB NXGN Com 49	901.2	3/14/25	Approved as Modified	Accepted the changes based on the commentors recommendations.
Chapter 10 REFERENCED STANDARDS				
Multi-chapter proposals				
ICC 1125 IS-MGOB GA Com 1	Throughout the document			Uses for MgO panels:
ICC 1125 IS-MGOB GA Com 2	Throughout the document			Interior sheathing:

Revisions to the text are in legislative format – strikeout of what is to be removed, and underlined for new. Revised text in the proposals in **red** is to highlight the changes that were modified by the committee.

Staff notes located in this document after a proponents reason are provided to indicate proposals that may require coordination; technical information; or terminology that is not good code language (e.g. “may” or “guarantee”, the use of “when” where the use is not a function of time). Staff notes are provided to assist the committee or proponent for possible modification. It is not intended to provide an opinion.